



NOTES:

1. SAND BEDDING SHALL CONFORM TO SECTIONS 200-1.5.3 AND 200-1.5.5 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (LATEST EDITION).
2. DENSIFICATION OF BEDDING SHALL BE ACCOMPLISHED IN CONFORMANCE WITH 306-1.2.1 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (LATEST EDITION).
3. BEDDING SHALL BE COMPACTED TO 95% OF MAXIMUM DENSITY UNDER STRUCTURES AND 90% ELSEWHERE.

ACCOMPANYING STD.'S T700 AND T116

CITY OF TORRANCE - ENGINEERING DEPARTMENT

DATE ISSUED

16 NOV 1998

BEDDING FOR WATER PIPE

RICHARD W. BURTT
ENGINEERING DIRECTOR
R.C.E. NO. 32862

STANDARD NO.

T701-1

SHEET 1 OF 1